SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA C22.2 No. 8 VDE APPROVED: EN 60939-2

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 20 AMP, 120/250 VAC,

16 AMP/40°C, 250 VAC

LINE FREQUENCY:

50-60Hz

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

.07mA @ 120V 60Hz @ 250V 50Hz .13mA

OPERATING AMBIENT TEMP. RANGE; -10°C TO +40°C @ RATED CURRENT, in.

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS № 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR

CUSTOMER DRAWING CATALOG # 20SRB1-X ECN# APPRVD DATE TAM 15-000476 190CT15

TEST SPECIFICATIONS:

INDUCTANCE: N/A

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: 1000 pF±20% LINE TO LINE: N/A

μF±20% DISCHARGE RESISTOR; N/A M n

L/G AND L/L I.R. ND DISCHARGE RESISTOR:

6000M ... (MIN.) @ 100VDC,

20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC FOR I MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

