


THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP.



PANDUIT P/N	WEIGHT
R2P	28.00 LB/EACH (12.70 KG/EACH)
R2PWH	28.00 LB/EACH (12.70 KG/EACH)


NOTES:

- CAN BE USED WITH ANY INDUSTRY STANDARD 19" COMPONENTS IN ADDITION TO ALL PANDUIT CABLE MANAGEMENT AND PATCH PANEL PRODUCTS.
- WILL HOLD UP TO 45 SINGLE RACK SPACINGS.
- EIA SPACING ON RACK: I.E., REF.
HOLE SPACING ON UPRIGHT CHANNELS:
.625, .625, .500, .625, .625, .500, ETC.
- ASSEMBLY IS REQUIRED.
- RACK PART THICKNESSES:
 - UPRIGHT CHANELS: WEB; .14 $\pm$.03
FLANGE; .19 $\pm$.03
 - TOP BRACKET: .19 $\pm$.03
 - BASE BRACKET: .25 $\pm$.03
- DIMENSIONS IN PARENTHESES ARE IN METRIC.
- ALL ASSEMBLY HARDWARE INCLUDED:
 - (12) 3/8-16 X 1" BLACK HEX HEAD CAP SCREW
 - (24) 3/8" PAINT PIERCING GROUNDING WASHER
 - (1) TUBE OF ANTI-OXIDIZING PASTE
 - (24) 12-24 X .5" SLOTTED PAN HEAD STEEL SCREWS
 - (12) 3/8-16 BLACK HEX NUTS
- LOAD RATING-1000 LBS.
- RU SPACING NUMBERS ARE CLEARLY PRINTED ON MOUNTING RAILS. RU NUMBERING IS BOTTOM-UP, WITH RU #1 AT BOTTOM AND RU #45 AT TOP.

TITLE			
7' CABLE MANAGEMENT RACK			
CUSTOMER DRAWING			
ITEM REVISION NAME		09V064AC/01	
DATASET FILE NAME		09V064AC_DC/01C	
UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE: IN (mm)		MATERIAL:	
.X $\pm$.XX $\pm$		ALUMINUM	
.XXX $\pm$ ANGLES $\pm$		DRAWING NUMBER:	
THIRD ANGLE PROJECTION		09V064AC_DC	
DRAWN BY	DATE	CHK	SCALE
BAME	5-26-10	DPN	NONE
SHT 1 OF 2			A

REV	DATE	BY	CHK	APR	DESCRIPTION	ECN
01C	11/11/15	BAME			ADDED P/N R2PWH	
01B	4/22/13	RYB			REDRAWN, NEW TITLE BLOCK	09V064AC_DC

THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP.



TITLE		7' CABLE MANAGEMENT RACK	
CUSTOMER DRAWING			
ITEM REVISION NAME	09V064AC/01	PANDUIT	
DATASET FILE NAME	09V064AC_DC/01B		
UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE: IN (mm)		MATERIAL:	
.X ± .XX ±		ALUMINUM	
.XXX ± ANGLES ±		DRAWING NUMBER:	
THIRD ANGLE PROJECTION		09V064AC_DC	
DRAWN BY	DATE	CHK	SCALE
BAME	5-26-10	DPN	NONE
SHT 2 OF 2		A	

REV	DATE	BY	CHK	APR	DESCRIPTION	ECN
01C	11/11/15	BAME			SEE SHEET 1 OF 2	
01B	4/22/13	RYB			SEE SHEET 1 OF 2	09V064AC_DC