

## BeStar Technologies Inc.

Address: 761 N. 17th Street Unit 4, St. Charles, IL 60174
Tel: 847-261-2850 E-mail: sales@bestartech.com Web: www.bestartech.com

Document Number : 0004-95 Revision : A5 **Total Pages** : 5

Prepare by : Loki, Lo

: 29 August, 2013 Date

# **SoniCrest** Brand Acoustic Components

www.jlsonicrest.com

Document Type : Specification

Product Type : Electro-magnetic Sound Generator Component

Part Number : HC0905A

A3 - Updated format and layout by Leo Sin on 29 Dec., 2003	
A4 - Updated RoHS version by Leo Sin on 17 May, 2006	
A5 - Updated section 6 by Loki, Lo on 29 Aug., 2013	

This material is the property of BeStar Technologies Inc. Unauthorized copying or use of this material is prohibited.

#### 1. Purpose and Scope

This document contains both general requirements, qualification requirements, and those specific electrical, mechanical requirements for this part.

## 2. Description

Ø9.5mm electro-magnetic sound generator, RoHS compliant.

## 3. Application

Telecommunication Equipment, Computers and Peripherals, Portable Equipment, Automobile Electronics, POS System, etc.

## 4. Component Requirement

## 4.1. General Requirement

**4.1.1.** Operating Temperature Range : -20°C to +60°C

**4.1.2.** Storage Temperature Range : -30°C to +70°C

**4.1.3.** Weight : Approx. 1g

#### 4.2. Electrical Requirement

**4.2.1.** Rated Voltage : 5V

**4.2.2.** Operating Voltage : 4V to 7V

**4.2.3.** Rated Current : <=80mA

**4.2.4.** Coil Resistance :  $40 \pm 4 \Omega$ 

**4.2.5.** Sound Pressure Level at 10cm :>=85dB

(Applying rated voltage)

**4.2.6.** Rated Frequency : 3200Hz




Figure 1. Frequency Response

## 4.3. Mechanical Requirement

#### 4.3.1. Layout and Dimension

: See Section 6, Figure 3

## 4.4. Test Setup




Figure 2. Test Setup

**Notes**: Apply 2.5Vo-p from Signal Generator, set rated signal from Signal Generator. Measure SPL using a calibrated SPL meter 10cm from the sound port. Sound level meter to be in accordance with IEC651 (1979) Type 1 and/or ANSI S1.4-1983. The meter must be checked on a daily basis using a calibrated acoustic calibrator recommended by the manufacturer. Measurement should be carried out in a free field environment or at least 40cm from any surface.

HC0905A

#### 5. Reliability Test

- **5.1. High Temperature**: Subject samples to  $+60 \pm 3$  °C and operate for 96 hours. Components must be fully stabilized at temperature extremes before data is taken, which may require up to a 2 hours soak.
- **5.2.** Low Temperature: Subject samples to  $-20 \pm 3$  °C and operate for 96 hours. Components must be fully stabilized at temperature extremes before data is taken, which may require up to a 2 hours soak.
- **5.3. Temperature Shock**: Each temperature cycle shall consist of 1 hour at -20°C followed by 1 hour at +60°C with a 20 seconds maximum transition time between temperature extremes. Test duration is for 32 cycles.
- **5.4. Static Humidity**: Precondition at +25°C for 1 hour. Then expose to +40°C with 90 to 95% relative humidity for 96 hours. Finally dry at room ambient for 2 hours before taking final measurement.
- **5.5. Random Vibration** : Secure samples. Vibrated randomly  $10\text{Hz} \sim 50\text{Hz} \sim 10\text{Hz}$  with 0.75mm peak amplitude and  $30\text{Hz} \sim 50\text{Hz} \sim 30\text{Hz}$  with 0.15mm peak amplitude. The test duration is 30 minutes per plane.
- **5.6. Mechanical Shock**: Secure samples as required. Then subject samples to half sine wave pules  $(100 \text{m/s}^2 \text{ for } 16 \text{ms})$  for a total of  $1000 \pm 10$  shocks.
- **5.7. Drop Test**: Drop samples naturally from the height of 1mm onto a wooden board six times.

**HC0905A** Page 5 of 5

## 6. Mechanical Layout

Unit: mm

Tolerance : Linear  $XX.X = \pm 0.3$ 

 $XX.XX = \pm 0.05$ 

Angular =  $\pm 0.25^{\circ}$ 

(unless otherwise specified)




Figure 3. HC0905A Mechanical Layout